



PENTAIR EQUIPMENT PROTECTION
HOFFMAN®
+1.763.421.2240 main
2100 Hoffman Way
Minneapolis, MN 55303
United States
pentairprotect.com

Declaration of Conformity

Issued by Manufacturer
Hoffman Enclosures, Inc. dba Pentair Equipment Protection 2100 Hoffman Way
Anoka, Minnesota 55303-1745, U.S.A.
declare at our sole responsibility, that these devices are designed and constructed according to
the fundamental safety and health requirements.

Enclosure Models: A**H*GQLRP, A**H*GQLRP3PT (Bulletin A17W3 and A17WM)
Equipment Description: Hoffman Wall Mount Fiberglass Enclosure
Enclosure Rating : NEMA / UL / cUL Type 3, 3R, 4, 4X, 12, 13
Enclosure Certification: UL508A Listed E61997

File E61997

Vol. 1

Sec. 2
and Report

Page 7

Issued: 1977-08-05

Revised: 2012-08-02

TYPES 3, 3R, 4, 4X, 12, AND 13 NO. A-*H*GQLRP,
FIBERGLASS ENCLOSURES - FIG. 4 (C84-17514)

Applicable Standards: UL508A Industrial Control Panel Enclosure
UL 50 Enclosures for Electrical Equipment, Non-
Environmental Considerations
UL 50E Enclosures for Electrical Equipment, Environmental
Considerations
cUL to CSA C22.2 No. 94.1 and 94.2
NEMA250 Enclosures for Electrical Equipment (1000 Volts Maximum)

Authorized by:

12/1/2015 (today's date)

Glen Kampa

Date

Senior Regulatory Engineer

DOC: CERT-00038 A

Subject to Change Without Notice

CERTIFICATE OF COMPLIANCE

Certificate Number 20121102 – E61997
Report Reference E61997 - 19981104
Issue Date 2012-NOVEMBER-02

Issued to: PENTAIR TECHNICAL PRODUCTS
2100 HOFFMAN WAY
ANOKA, MN 55303 USA


This is to certify that representative samples of Industrial Control Panels
Types 3, 3R, 4, 4X, 12, and 12K enclosures and external field installed accessory kits.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL 508A, "Industrial Control Panels" and CSA-C22.2 No. 14, "Industrial Control Equipment."

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  vs the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

