



**BradyGlo™ Exit Signs are UL Approved for Fluorescent, Mercury Vapor & Metal Halide Light Sources.**

## ► Frameless Exit Signs



Reflective

Catalog No.	Description
87807	Red Exit
87808	Green Exit
98450	Red Exit - NYC Compliant
98452	Red Reflective
98453	Green Reflective

## BradyGlo™ Exit Signs are Compliant with...

- Listed to UL 924 and ULC 924 Canada. Now approved with fluorescent, mercury vapor and metal halide lighting.
- NFPA Life Safety Code 101 (7.10, 7.10.1.2, 7.10.1.5, 7.10.1.6, 7.10.2, 7.10.7.2, A7.10.7.2, 13.4.7.4.2, 13.4.7.4.3)
- NFPA Life Safety Code 101B (Sections 3-10.1.5, 3-10.1.6)
- NFPA 5000 Building Construction & Safety Code (Sections 12.10.1.5, 12.10.1.6)
- 2003 International Building Code (Sections 411.7, 1011)
- 2000 International Building Code (Section 1003.2.10)
- 1999 BOCA National Building Code (Section 1023)
- 1999 Standard Building Code (Section 1016.3)
- 1997 Uniform Building Code (Sections 1003.2.8, 1007.2.7, 1007.6.2)
- OSHA 1910.37
- 1998 California Building Code - High Level & Low Level Exit Sign Regulations (1003.2.8, 1007.2.7, 1007.2.8, 1007.2.9, 1007.3.12, 1007.5.13, 1007.6.2a, 1007.6.2.1a)
- 1998 California Fire Code (Sections 1211, 1212, 3214, 4110, 4111)
- State of California Statutes and Regulations (Sections 13143, 17920.8, 1007.2.7, 1007.2.8, 1007.2.9, 1007.3.12, 1007.5.13, 1007.6.2a, 1007.6.2.1a)
- ICC Evaluation Service, Report #ER-6153
- Department of Defense United Facilities Criteria on Fire Protection Engineering for Facilities, April 17, 2003

## Technical Data

	Framed:	Frameless:
<b>Color:</b>	High Visibility Green	High Visibility Green
<b>Sizes:</b>	8.25" x 15.25" x .25"	7.5" x 13" x .075"
<b>Letter Size:</b>	.875" stroke with 7" height	.8125 stroke with 6" height
<b>Background:</b>	Black, Green, Red, White	Photoluminescent
<b>Directional:</b>	Pop out chevron, 2 included	Field Applied
<b>Viewing Direction:</b>	50 feet	50 feet
<b>Life expectancy:</b>	25+ years	25+ years
<b>Construction:</b>	.035 painted steel/PL panel	PL panel/Red or Green lettering
<b>Electric Requirements:</b>	NA	NA

**Installation:** Framed Signs can be surface, flag or ceiling mounted. All hardware included. Unframed Signs can be surface mounted High- or Low-Level. During installation it must be determined that there is a minimum of 54 lux of Fluorescent, Mercury Vapor or Metal Halide light on the face(s) of the signs at all times during building occupancy.