



## Product Bulletin

Product: P4010ACLEDS-2, P4010ACLEDS-2 & SLED177i

### Announcement

All strobe products produced after October 22, 2021 will only meet UL 1638 and no longer meet ADA, FHA, HUD, and UL 1971.

### Applies to

All Kidde customers with orders pending or future orders for P4010ACLEDS-2, P4010ACLEDS-2, and SLED177i

### Affected products

P4010ACLEDS-2, P4010ACLEDS-2 & SLED177i

### Background

- Kidde was made aware of a change to the UL 1971 standard regarding the strobe light pulse duration to 20 ms (milliseconds)
- At this time, the strobe light pulse duration on our products are ~ 50ms, consequently we have removed these products from our portfolio
- Timing for updated products is approximately ~6 months

### What should you do?

Please contact any customers that currently have a backorder with the impacted models and make them aware these models are no longer listed under ADA, FHA, HUD, and UL 1971.

Unless a local ordinance specifies otherwise, any P4010ACLEDS-2, P4010ACLEDS-2, and SLED177i products produced prior to October 22<sup>nd</sup> 2021 are NOT impacted by this transition.

Therefore, anything already installed or in inventory still meets ADA, FHA, HUD, and UL 1971.

Contacting support

**For Business Customer Support – Call 1-800-654-9677**

Open Monday through Friday from 8:00 AM – 5:00 PM EST